


Fall Inspection (Rooftops, Split Systems, Gas Fired Devices)



- Provide disposable pleated air filters (4 X per year)
- Belts (check tension and alignment) – adjust as needed
- Grease and/or oil all Pumps, Circulators, and all other heating equipment
- Check and Record all Volts and Amps (total unit, fans, pumps, circs)
- Check and Record all Temperature rises (Water and/or Air)
- Verify Fan switch operation
- Clean Burners and Burner tubes
- Inspect Igniters
- Inspect heat exchangers for cracks
- Test all limit switches
- Test any/all burner safety controls
- Check crankcase heater
- Inspect gas lines
- Check Economizer for proper operation (if applicable)
- Check and Record Intake and Manifold Gas Pressures to Every Piece of Equipment
- Provide detailed report of each piece of equipment if required by Customer

For OIL Gas Boilers, Furnaces



- Full Combustion / Efficiency Test (and Report)
- Replacement of Nozzles, Filters, Electrodes, and strainers
- Cleaning of Exchanger and all Burner Assembly